



**GOVERNMENT OF TAMIL NADU**

**DEPARTMENT OF PUBLIC HEALTH AND PREVENTIVE MEDICINE**

**SANITARY CERTIFICATE 2023-2024**

(Under Tamil Nadu educational rules) (Appendix-3 and Chapter III Rule : 24)

I hereby declare that I have inspected the VIJAY VIDHYA MANDIR (CBSE), EMOOR, KARUR DISTRICT - 639 007 building and premises on the day of 10.04.2023 and certify

- : that the accommodation provided for the student studying in this school is sufficient for the minimum number of students studying there in and is properly ventilated and lighted;
- : that is neat and clean ;
- : that the building is maintained in substantial repair ;
- : that the latrine arrangement are adequate and satisfactory ;
- : that the supply of drinking water is wholesome ; and
- : that in all necessary respects the sanitation is good.

This Certificate is issued subject to the following conditions


1. The garbage generated within the home premises should be collected and disposed off properly.
2. On any account the garbage should not be burnt.
3. On inspection Water, Sanitation, Drainage and Septic Tank facility should be maintained properly.
4. No sullage / sewage should be let out into street or in any other watercourse.
5. The building should not be placed for fly nuisance.
6. The building should not be placed for mosquito nuisance.
7. The building should not be placed for infective disease like ADD, Cholera and Other Communicable diseases.
8. The solid waste should be disposed by hygienic method.
9. If the building is not properly maintained, the certificate is liable to be cancelled.
10. SOP for Covid 19 should be followed in your Campus, As per norms a qualified Health Inspector should be appointed and to be informed to this office.
11. This Sanitary Certificate is valid for One Year.

*E. Meganathan*

**E. MEGANATHAN,**  
PRINCIPAL,  
VIJAY VIDHYA MANDIR,  
EMOOR, KARUR-639 005,

Date :

*S. B. C. 2023/2024*  
**BLOCK HEALTH SUPERVISOR,**  
GOVT. COMMUNITY HEALTH CENTER,  
UPPIDAMANGALAM, KARUR.



*12/4/23*  
COUNTER SIGNED

**DEPUTY DIRECTOR**  
DEPUTY DIRECTOR HEALTH SERVICES,  
KARUR.

K.Dis.No.2187/E4/2023

Office of Health Services,  
Dated. 13.04.2023

Sub: Public Health and Preventive Medicine - Karur District-  
VIJAY VIDHYA MANDIR (CBSE) - Sanitary Certificate for the year  
2023 - 2024- issued regarding.

Ret: Application dated.27.03.2023, VIJAY VIDHYA MANDIR (CBSE),  
Emoor, Karur District - 639 007.

(( ( ))

With reference to the above, the Sanitary Certificate for VIJAY VIDHYA  
MANDIR (CBSE), Emoor, Karur District - 639 007 is issued for the year  
2023 - 2024.

Encl:- Sanitary Certificate for 2023 - 2024

*DK*  
*13/4*  
Deputy Director of Health Services  
Karur

*R*  
*13/4/2023*

To:  
VIJAY VIDHYA MANDIR (CBSE),  
Emoor,  
Karur District - 639 007.

**E. MEGANATHAN,**  
PRINCIPAL,  
VIJAY VIDHYA MANDIR,  
EMOOR, KARUR-639 005.



-: TEST WATER BEFORE TASTE :-  
TAMIL NADU WATER SUPPLY & DRAINAGE BOARD  
DISTRICT LEVEL WATER TESTING LABORATORY

No 116/1, Bala Arcade, Poonga Nagar, Dindigul Main Road, Thanthonimalai, Karur - 639005

**TEST REPORT**

**Ph: 04324-255455**

From  
ER S.Yogaraj M.E  
Assistant Engineer  
TWAD Board, DWT Lab,  
RWS Division Karur

To  
Vijai Vidhya Mandhir School(CBSE),  
Emur, Thanthonimalai, Karur

Lr.No: 37258 AE /TWAD Lab/ Krr 2023 Dated: 30.05.23  
Sir, Sub: Examination of water sample - Report furnished - Reg.  
Ref : 1) Your Lr.No Nil  
2) T.O Invoice No. 5412/dt 26.05.2023 for Rs 1652 /-

The results of analysis for the water sample sent under reference is furnished below.

Sample No			L.N 37258
Date of Collection			26.05.23
Date of Receipt			26.05.23
Date of Test Completed			30.05.23
Source			RO water
Location of Sampling			In Side The Campus
Habitation			Emur
Panchayat			Emur
Union			Thanthoni
Collected by			Customer
BIS 10500 : 2012	<i>Acceptable limit</i>	<i>Permissible limit in the absence of</i>	Result for Water sample No:
I PHYSICAL EXAMINATION			L.No 37258
1 Appearance	--	--	Clear
2 Colour (Pt.Co - scale)	5	15	Colourless
3 Odour	Agreeable	0	None
4 Turbidity NT units	1	5	0
5 Total dissolved solids, mg/L	500	2000	79
6 Electrical conductivity micro mho/cm	--	--	113
II CHEMICAL EXAMINATION			
7 Ph-Alkalinity as CaCO <sub>3</sub> mg/L			0
8 Calcium as Ca mg/L	75	200	12
9 Magnesium as Mg mg/L	30	100	6
10 Sodium as Na mg/L	--	--	0
11 Potassium as K mg/L	--	--	0
12 Iron as Fe mg/L	0.3	1.0	0.00
13 Manganese as Mn mg/L	0.1	0.3	0
14 Free Ammonia as NH <sub>3</sub> mg/L	0.5	0.5	0.00
15 Nitrite as NO <sub>2</sub> mg/L	--	--	0.00
16 Phosphate as PO <sub>4</sub> mg/L	--	--	0.00
17 Tidy's Test 4hrs as O <sub>2</sub> mg/L	--	--	0.00
18 Free residual chlorine mg/L	0.2	1.0	0.0
III BACTERIOLOGICAL EXAMINATION			
1 Fecal coliform (colonies per 100 ml)	0	0	0

REPORT 37258: The water is Physically, chemically Potable and Bacteriologically Not contaminated

*E. MEGANATHAN*

**E. MEGANATHAN,  
PRINCIPAL,  
VIJAY VIDHYA MANDIR,  
EMOOR, KARUR-639 005.**

*S. Yogaraj* 30/5/23

Assistant Engineer  
TWAD Board, DWT Lab,  
RWS Division Karur



WATER SUPPLY & DRAINAGE BOARD  
TAMIL NADU WATER SUPPLY & DRAINAGE BOARD  
DISTRICT LEVEL WATER TESTING LABORATORY



No 116/1, Bala Arcade, Poonga Nagar, Dindigul Main Road,  
Thanthonimalai, Karur - 639005

E Mail twadlabkarur@gmail.com

Phone No: 04324-255455

Doc No DWTL/Form 7.8/01

ULR No TC1076622000037258	30.05.23
Invoice Details 5412/ dt 26.05.2023 Amt Rs 1652 /-	Sample /Lab No 2023/37258
Client Name & Address Contact Number and E Mail ID	Vijai Vidhya Mandhir School(CBSE), Emur, Thanthonimalai, Karur
Sample Name	Water
Sample Description	RO
Sample Submitted by	Customer
Location & Date	School Campus, 26.05.23
Quantity of sample Received	2 L
Sample Container	Jerry cane
Sample Condition on Receipt	Good
Sample Received On	26.05.23
Test Commenced on	26.05.23
Test Completed on	30.05.23
Environmental Condition	25.3 <sup>0</sup> C

S.No	Parameters	Test Method	Unit	Result	Specification as per IS 10500 : 2012	
					Acceptable Limits	Permissible Limit
1	pH	IS 3025 part 11-1983	--	7.04	6.5-8.5	6.5-8.5
2	Total Alkalinity	IS 3025-part 23-1986	mg/L	12	200	600
3	Total Hardness as CaCO <sub>3</sub>	IS 3025 part 21-2009	mg/L	24	200	600
4	Nitrate as NO <sub>3</sub>	APHA 23rd Edn 2017-4500 -NO3 B	mg/L	< 2	45	45
5	Chloride as Cl	IS 3025-part 32-1988	mg/L	28	250	1000
6	Fluoride	APHA 23rd Edn 2017 - 4500- F-D	mg/L	< 0.2	1	1.5
7	Sulphate	IS 3025-part 24-1986	mg/L	< 5	200	400

*S. Y. Jeyaraj* 5/6/23

Authorised Signatory  
Assistant Engineer  
RWS Division Karur

Note:

- The test results relate only to the items tested.
- The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
- Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
- The Result applied to the sample as Received basis
- Sampling not done by the laboratory.

Issue No./Date	01/01.10.2021	A.No	00/ --	Page No	1 of 1
----------------	---------------	------	--------	---------	--------

*E. MEGANATHAN*  
E. MEGANATHAN,  
PRINCIPAL,  
VIJAY VIDHYA MANDIR,  
EMOOR, KARUR